

BALL IMPACT TESTS

Troldekt acoustic panels have been tested and certified in accordance with 'Prüfung der Ballwurfsicherheit, DIN 18032, Teil 3 "Sporthallen für Turnen und Spiele" (requirements and testing of ball impact safety, DIN 18032, Part 3, sports facilities).

Certificate	Ceiling/ Wall	Troldekt®	Construction	Valid until:
903 2291 000-6/Man/Sgm	Ceiling	25 mm extreme fine structure	Direct installation on wooden battens per 60 cm, joists per 100 cm	24.10.2020
903 2291 000-5/Man/Sgm	Ceiling	25 mm A2 fine structure		
903 2291 000-7/Man/Sgm	Ceiling	25 mm fine structure		
903 2291 000-4/Man/Sgm	Ceiling	25 mm coarse structure		03.08.2019
903 0341 000-6/Ma/Whr	Ceiling	25 mm ultrafine structure		
903 4843 000/Man/Sgm	Ceiling	25 mm A2 extreme fine structure		
903 2291 000-10/Man/Sgm	Wall	25 mm fine structure	Direct installation on wooden battens per 30 cm, joists per 60 cm	24.10.2020
903 2291 000-11/Man/Sgm	Wall	35 mm coarse structure		
903 2990 000-3/Man/Sgm	Wall	25 mm coarse structure		31.01.2021
903 2990 000-4/Man/Sgm	Wall	25 mm ultrafine structure		
903 2291 000-1/Man/Sgm	Wall	25 mm extreme fine structure	Direct installation on wooden battens per 60 cm, joists per 60 cm	24.10.2020
903 2291 000-2/Man/Sgm	Wall	35 mm ultrafine structure		
903 2291 000-3/Man/Sgm	Ceiling	25 mm extreme fine structure		
903 0341-000-4/Ma/Whr	Ceiling	25 mm fine structure		03.08.2019
903 0341-000-5/Ma/Whr	Ceiling	25 mm ultrafine structure		
903 2990 000-6/Man/Sgm	Wall	35 mm fine structure		31.01.2021
903 2990 000-2/Man/Sgm	Wall	25 mm A2 ultrafine structure		
903 2990 000-5/Man/Sgm	Wall	25 mm A2 fine structure		
903 0341-000-2/Ma/Whr	Ceiling	25 mm fine structure		
903 0341-000-1/Ma/Whr	Ceiling	25 mm coarse structure		03.08.2019
903 0341 000-3/Ma/Whr	Ceiling	25 mm ultrafine structure		
903 2291 000-9/Man/Sgm	Ceiling	25 mm A2 fine structure	On suspended C60 profiles per 60 cm	
903 2291 000-8/Man/Sgm	Ceiling	25 mm extreme fine structure		24.10.2020
903 2990 000-1/Man/Sgm	Ceiling	25 mm A2 ultrafine structure		31.01.2021
903 4843 000/Man/Sgm	Ceiling	25 mm A2 extreme fine structure		15.05.2020
903 0341-000-7/Ma/Whr	Ceiling	35 mm fine structure KN	Concealed installation (KN) on wooden battens per 60 cm, joists per 100 cm	03.08.2019
903 5939-000/Man/Sgm	Ceiling with access panel	25 mm ultrafine structure	On suspended C60 profiles per 60 cm, access panel 60 cm x 60 cm / 60 cm x 120 cm	17.09.2020